

Energy Task Force


Pre-insulated Pipe

2475 Clark St • Apopka, Fl 32703 • 407-523-3770 • 407-523-3722

ETF-LT Product Specification

Piping system for LN2, CO2, O2, Ammonia, chilled water or process piping.
ETF-LT pre-insulated pipe shall consist of the following components:

- Carrier Pipe:** Type K hard drawn copper tubing conforming to ASTM-B-88 in 20-foot lengths, may be Nitrogen purged, cleaned & capped
- Insulation:** Polyurethane foam: K Factor 0.14, Density 2.0 to 3.0 PCF, 90-95% closed cell conforming to mil spec -1-24172 and ASTM-C-591 completely filling the annular space between carrier pipe and jacket. Maximum service temperature of 250°
- Jacketing Material:** High impact seamless polyvinyl chloride (PVC) class 12454 B compound conforming to ASTM 1784 Type 1, Grade 1. For jacket thickness see attached schedule
- End Seal:** Mastic end seal factory applied to insulation ends.
- Insulation of Straight Joints:** Prior to joining carrier pipe a PVC sleeve is slid onto jacketing on either side of joint. After soldering or brazing and hydro testing, the PVC sleeve is slid in place and sealed with pressure sensitive tape. Polyurethane foam is then mixed and poured into the annular space and sealed watertight.
- Fittings:** All fittings be Prefabricated / Pre-insulated by ETF or contractor supplied, field welded and insulated utilizing Energy Task Force fitting insulation kits. Fitting kits consist of hard shell mitered PVC cover matching thickness of jacket, polyurethane foam and pressure sensitive tape.
- Backfilling:** Underground systems shall be buried in a trench of not less than 24 inches deeper than the top of the pipe jacket and not less than 18 inches wider than the combined O.D. of all piping systems. Backfill should be tamped compactly in place. No rock shall be used in the first foot of the backfill. To meet H-20 highway loadings, there must be 24 inches from top of jacket to grade of the compacted fill.



Energy Task Force

Pre-insulated Pipe

2475 Clark St • Apopka, Fl 32703 • 407-523-3770 • 407-523-3722

Table 1: Specified Carrier Pipe / PVC Jacket

Nominal Pipe Size	Minimum Insulation Thickness	Nominal Jacket Size	Jacket Thickness
1/2"	1.7"	4.0	60 mils
1/2"	2.7"	6.0	70 mils
3/4"	1.6"	4.0	60 mils
3/4"	2.6"	6.0	70 mils
1"	1.4"	4.0	60 mils
1"	2.4"	6.0	70 mils
1 1/4"	2.3"	4.0	60 mils
1 1/4"	1.3"	6.0	70 mils
1 1/2"	1.2"	4.0	60 mils
1 1/2"	2.2"	6.0	70 mils
2"	1.9"	6.0	70 mils
2"	2.9"	8.0	80 mils
2 1/2"	1.7"	6.0	70 mils
2 1/2"	2.7"	8.0	80 mils
3"	1.4"	6.0	70 mils
3"	2.4"	8.0	80 mils

ENERGY TASK FORCE LLC WARRANTY

Energy Task Force LLC warrants its products only to the extent that it will replace those proved to have manufactured defects, within a one-year period from date of delivery. Energy Task Force must be provided an opportunity to inspect an alleged defective product and the installation application. This warranty does not provide for the expenses incurred for removal, re-installation or consequential damages arising from the defective material. There is no warranty other than that described above, and no one is authorized to issue any other warranty related to Energy Task Force LLC products.